

EU Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration, pressure device:

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX,
Differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX.Manufacturer: **APLISENS S.A., ul. Morelowa 7, 03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX, differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX in all versions comply with directive:

- **EMC – 2014/30/EU** dated 26 February 2014

Conformity assessment procedure: module A. The following standard was applied EN 61326-1:2013.

- **RoHS – 2011/65/EU** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC of the European Parliament and of the Council. The following standard was applied: EN 50581:2012.

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX, differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX in intrinsically safe versions comply with directive:

- **ATEX – 2014/34/EU** dated 26 February 2014

Intrinsically safe versions of transmitters are marked with the following certificate marking:

II 1/2G Ex ia IIC T5/T4 Ga/Gb
II 1D Ex ia IIIC 105°C Da
I M1 Ex ia I Ma (version with ss316 housing)
KDB 19 ATEX 0011X

Conformity assessment procedure: module B. NB no.1026, Physical Technical Testing Institute, Pikartska 7, 716 07 Ostrava Radvanice.

The following standards were applied: EN 60079-0:2012+A11:2013, EN 60079-11:2012, EN 50303:2000.

Pressure transmitters **APC-2000ALW Safety** ID: 0001 0004 0002 XXXX XXXX XXXX XXXX XX, differential pressure transmitters **APR-2000ALW Safety** ID: 0002 0004 0002 XXXX XXXX XXXX XXXX XX, in explosion-proof versions are marked with the following certificate marking:I M2 Ex db ia I Mb (version with ss316 housing) I M2 Ex db ia I Mb (version with ss316 housing)
II 1/2G Ex ia / db IIC T6/T5 Ga/Gb or II 2G Ex ia / db IIC T6/T5 Gb
II 1/2D Ex ia / tb IIIC T105°C Da/Db II 2D Ex ia / tb IIIC T105°C Db

KDB 19 ATEX 0011X

Conformity assessment procedure: module B. NB no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

The following standards were applied: EN 60079-0:2012+A11:2013, EN 60079-1:2014, EN 60079-11:2012, EN 60079-26:2015, EN 60079-31:2014.

Notification of quality assurance: module D. NB no.1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

Warsaw, 05.06.2019

Adam Żurawski
General Manager