



EC-Type Examination Certificate

- (1)
(2) **Equipment or Protective Systems Intended for Use
in Potentially Explosive Atmospheres
(Directive 94/9/EC)**

- (3) EC-Type Examination Certificate Number:


FTZÚ 14 ATEX 0174X

- (4) Equipment or protective system: **Temperature sensor type CT AL...;
and Temperature transmitter type APT AL...**
- (5) Manufacturer: **APLISENS S.A.**
- (6) Address: **ul. Morelowa 7, 03-192 Warszawa, Poland**
- (7) This equipment or protective system and any of acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- (8) The Physical Technical Testing Institute, notified body number 1026 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report N°:

14/0174 dated 19.11.2015

- (9) Compliance with Essential Health and Safety Requirements has been assured by compliance with:
EN 60079-0:2012; EN 60079-1:2007; EN 60079-31:2009; EN 60079-26:2007
- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-Type Examination Certificate relates only to the design, examination and testing of the specified equipment or protective system in accordance to the directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- (12) The marking of the equipment or protective system shall include following:

 **II 1/2G Ex d IIB+H₂ T** Ga/Gb or II 2G Ex d IIB+H₂ T** Gb - see (15)**

 **II 1/2D Ex tb IIIC T* Da/Db or II 2D Ex tb IIIC T* Db - see (15)**

This EC-Type Examination Certificate is valid till: **30.11.2020**

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 20.11.2015

Page: 1/4

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.



**Physical Technical Testing Institute
Ostrava – Radvanice**

(13)

Schedule

(14) **EC-Type Examination Certificate N° FTZÚ 14 ATEX 0174X**

(15) **Description of Equipment or Protective System:**

Temperature sensor CT AL... and temperature transmitter type APT AL... consist of measuring insert, which on the one end contains sensing resistors or thermocouples. The second end of the measuring insert is provided with terminal block or transmitter protected by connection head with Ex- protection Ex d for gas and Ex- protection Ex tb for dust. Aluminium alloy head consists of cover with thread M72x1.5 and body with thread hole M20x1.5 or 1/2 NPT for Ex cable gland.

Opening d2 in the connection head body along with bush on the measuring insert creates flameproof joint.

Marking of the equipment:

Ex II 2G Ex d IIB+H₂ T Gb and II 2D Ex tb IIIC T* Db** - location of complete equipment in zone 1 or zone 21.

Ex II 1/2G Ex d IIB+H₂ T Ga/Gb and II 1/2D Ex tb IIIC T* Da/Db** – measuring stem with screwed to the opening D2 of housing thermowell, with proper wall thickness (zone 0 or 20):

- a) minimum 1.5 mm, made of corrosion resistant steel or
- b) minimum 1 mm and fixed in protective thermowell (wall thickness minimum 1 mm) made of corrosion resistant steel.

Basic technical parameters:

The maximum measuring current of thermometric resistors:

- a) thin-film: Pt100 - 1 mA; Pt500 - 0.7 mA; Pt1000 - 0.3 mA
- b) wire – wound resistor: 5 mA

The current load of thermometric resistors Pt100, Pt500, Pt1000 or thermocouples - max. 10 mA


Maximum rated transmitter parameters:

Rated voltage Un: 7.5 V - 36 V DC
Rated current signal with HART: 4 - 20 mA
Degree of IP protection: IP 66

(16) Report No.: FTZÚ 14/0174

dated 19.11.2015

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 20.11.2015

Page: 2/4

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

FTZÚ, s.p., Pikartská 1337/7, 716 07 Ostrava-Radvanice, Czech Republic,
tel +420 595 223 111, fax +420 596 232 672, ftzu@ftzu.cz, www.ftzu.cz



**Physical Technical Testing Institute
Ostrava – Radvanice**

(13)

Schedule

(14) **EC-Type Examination Certificate N° FTZÚ 14 ATEX 0174X**

(17) Special conditions for safe use:

17.1 Temperature class (T^{**} for gas) or the maximum surface temperature (T^* for dust) depends mainly on the process temperature T_p (temperature-controlled medium) and methods of installation on site. Accordingly, the temperature T_p of the hottest place on the housing surface (which is the thermowell of the sensor), which has the contact with the explosive atmosphere in conditions of installation on site, has to be determined and one should follow the current instruction.

Temperature class T^{**}	Maximum surface temperature T^* for dust	Maximum temperature of medium
T6	85 °C	80°C
T5	100°C	95°C
T4	135°C	130°C
T3	200°C	195°C
T2	300°C	290°C
T1	450°C	440°C

17.2 Verified values of the maximum gaps and minimum constructional length of flameproof joints of this enclosure differ from relevant minimum and maximum values mentioned in standard. To obtain information about joints dimension it is necessary to contact the manufacturer.

17.3 Ambient temperature for housing and cable gland: T_{amb} : -50°C to +60°C.


17.4 Cable glands shall be used according to manufacturer's specification mentioned in user manual.


17.5 It must be kept IP degrees of sensor connection to the vessel wall minimum IP 67.

(18) Essential Health and Safety Requirements:

They are included in standards, which are mentioned in clause (9) of this certificate. The product was approved in accordance with above mentioned standards.

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 20.11.2015

Page: 3/4

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

FTZÚ, s.p., Pikartská 1337/7, 716 07 Ostrava-Radvanice, Czech Republic,
tel +420 595 223 111, fax +420 596 232 672, ftzu@ftzu.cz, www.ftzu.cz



Physical Technical Testing Institute
Ostrava – Radvanice

(13)


Schedule


(14) **EC-Type Examination Certificate N° FTZÚ 14 ATEX 0174X**

(19) List of Documentation:

- User manual:	DTR.CT.APT.AL	07/2014	
- Technical description:	CT AL-003	04/2015	
- List of documents:	CT AL-001-00	07/2014	
- Drawings No.:			
CTTBZN-008	02/2014	CTO-B190-Z	09/2013
CTTBZN-009	04/2014	CTO-C215-TA	09/2013
CT AL-002	03/2014	CTO-C218-01	10/2013
CTO-B177-TA	04/2015	CTA-C150-01	04/2015
CTO-B187-Z	04/2015	CTA-C151-01	04/2015
X-902-00	07/2014	CTA-C152-TA	09/2013
CT AL-A001-TA	04/2015	CTA-C156-01	10/2013
APT AL-A002-TA	04/2015	CTA-C157-01	10/2013
CT AL-A004-TA	06/2014	CTO-B189-TA	04/2015
APT AL-A001-TA	04/2015	CTW2-B002-TA	07/2013
CT AL-A002-TA	04/2015	CTW2-B003-TA	04/2015
APT AL-A004-TA	06/2014	CTO-B179-TA	07/2013
LI24ALW-C022-01	07/2014	CTO-B178-TA	06/2014
CTA-C190-01	07/2014	CTA-C171-TA	06/2014
CTO-B191-TA	05/2014	CTO-C214-01	09/2013
CTO-B192-TA	06/2014	CTO-B188-TA	08/2013
CTO-B193-TA	05/2014	CTW2-B001-TA	02/2013
CTO-B194-TA	05/2014	CTO-B197-Z	02/2014
CTO-B195-TA	05/2014	CTO-B198-Z	03/2014
CTO-B196-TA	05/2014		

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 20.11.2015

Page: 4/4

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

FTZÚ, s.p., Pikartská 1337/7, 716 07 Ostrava-Radvanice, Czech Republic,
tel +420 595 223 111, fax +420 596 232 672, ftzu@ftzu.cz, www.ftzu.cz



(1) **Supplementary EU - Type Examination Certificate No.1**

(2) **Equipment or Protective Systems Intended for Use
in Potentially Explosive Atmospheres
(Directive 2014/34/EU)**

(3) EU - Type Examination Certificate number:

FTZÚ 14 ATEX 0174X

(4) Product: **Temperature sensor type CT AL... and Temperature transmitter type APT AL...**

(5) Manufacturer: **APLISENS S.A.**

(6) Address: **ul. Morelowa 7, 03-192 Warszawa, Poland**

(7) This supplementary certificate extends EC - Type Examination Certificate No. FTZÚ 14 ATEX 0174X to apply to products designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.


(8) The Physical-Technical Testing Institute, Notified Body number 1026, in accordance with Articles 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26.02.2014, certifies that this product, as modified by this supplementary certificate, has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

(9) In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20.04.2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20.04.2016.

(10) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:


EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-26:2015, EN 60079-31:2014

(11) The marking of the product shall include the following:

 **II 1/2G Ex db IIB+H₂ T** Ga/Gb or II 2G Ex db IIB+H₂ T** Gb - see (15)**
II 1/2D Ex tb IIIC T* Da/Db or II 2D Ex tb IIIC T* Db - see (15)

(12) This certificate is valid till: **30.11.2025**

Responsible person:


Dipl. Ing. Lukáš Martinák

Head of Certification Body



Date of issue: 30.11.2020

Page: 1/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

Physical-Technical Testing Institute, s.p., Pikartská 1337/7, 716 07 Ostrava - Radvanice, Czech Republic
tel.: +420 595 223 111, +420 604 203 525, e-mail: ftzu@ftzu.cz, www.ftzu.cz



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13)

Schedule

(14) **Supplementary EU - Type Examination Certificate No. 1
to FTZÚ 14 ATEX 0174X**

(15) Description of the variation to the Product:

The subjects of this supplementary certificate are:

- Evaluation according to the newest standards.
- Prolongation of certificate validity.

Marking of the equipment:

⊕ II 2G Ex db IIB+H₂ T** Gb and II 2D Ex tb IIIC T* Db - location of complete equipment in zone 1 or 21.

⊕ II 1/2G Ex db IIB+H₂ T** Ga/Gb and II 1/2D Ex tb IIIC T* Da/Db – measuring stem with thermowell is screwed to the opening D2 of housing and fixed in protective thermowell (zone 0 or 20):

- a) from stainless steel with proper wall thickness 1,5 mm, or
- b) from stainless steel with proper wall thickness 1 mm mounted in the additional protective thermowell with proper wall thickness 1mm.

The equipment is verified according to the newest standards EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-26:2015 and EN 60079-31:2014.

Design of flameproof enclosure and electrical parameters remain unchanged.

(16) Report Number: 14/0174/1

(17) Specific Conditions of Use:

None additional to those listed previously.

(18) Essential Health and Safety Requirements:

Compliance with the Essential Health and Safety Requirements is covered by standards mentioned in clause (10) of this supplementary certificate.

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 30.11.2020

Page: 2/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

Physical-Technical Testing Institute, s.p., Pikartská 1337/7, 716 07 Ostrava - Radvanice, Czech Republic
tel.: +420 595 223 111, +420 604 203 525, e-mail: ftzu@ftzu.cz, www.ftzu.cz



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13)


Schedule

(14) **Supplementary EU - Type Examination Certificate No. 1
to FTZÚ 14 ATEX 0174X**

(19) Drawings and Documents:

Number	Revision	Sheets	Date	Description
CT AL-003	--	2	09/2020	Technical description
CT APT-001-02	--	1	09/2020	Description of changes No. 1
DTR.CT.APT.AL	B	27	09/2020	User manual
CT AL-001-00	--	2	09/2020	List of documentation
CTTBZN-008	--	1	09/2020	Drawing label APT-AL...
CTTBZN-009	--	1	09/2020	Drawing label CTAL...
CTO-B197-Z	--	1	09/2020	List of used Ex - cable glands
CT AL-A001-TA	--	1	09/2020	Drawing CT AL-GB3...
CT AL-A002-TA	--	1	09/2020	Drawing CT AL-GN3...
CT AL-A004-TA	--	1	09/2020	Drawing CT AL...
APT AL-A001-TA	--	1	09/2020	Drawing APT AL-GB3
APT AL-A002-TA	--	1	09/2020	Drawing APT ALGN3
APT AL-A004-TA	--	1	09/2020	Drawing APT AL...
CTTBZN-010	--	1	11/2020	Drawing of warning label

Responsible person:


Dipl. Ing. Lukáš Martinák
Head of Certification Body



Date of issue: 30.11.2020

Page: 3/3

This certificate is granted subject to the general conditions of the FTZÚ, s.p.
This certificate may only be reproduced in its entirety and without any change, schedule included.

Physical-Technical Testing Institute, s.p., Pikartská 1337/7, 716 07 Ostrava - Radvanice, Czech Republic
tel.: +420 595 223 111, +420 604 203 525, e-mail: ftzu@ftzu.cz, www.ftzu.cz



(1) **Supplementary EU - Type Examination Certificate No.2**

(2) **Equipment or Protective Systems Intended for Use
in Potentially Explosive Atmospheres
(Directive 2014/34/EU)**

(3) EU - Type Examination Certificate number:

FTZÚ 14 ATEX 0174X

(4) Product: **Temperature sensor type CT...**

(5) Manufacturer: **APLISENS S.A.**

(6) Address: **ul. Morelowa 7, 03-192 Warszawa, Poland**

(7) This supplementary certificate extends EC - Type Examination Certificate No. FTZÚ 14 ATEX 0174X to apply to products designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

(8) The Physical-Technical Testing Institute, Notified Body number 1026, in accordance with Articles 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26.02.2014, certifies that this product, as modified by this supplementary certificate, has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.


(9) In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20.04.2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20.04.2016.

(10) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-26:2015, EN 60079-31:2014

If the sign "X" is placed after the certificate number, it indicates that the product is subject to Specific Conditions of Use specified in the schedule to this certificate.

(11) The marking of the product shall include the following:

 **II 1/2G Ex db IIB+H₂ T** Ga/Gb** or **II 2G Ex db IIB+H₂ T** Gb** - see (15)
II 1/2D Ex tb IIIC T₂₀₀ °C Da/Db or **II 2D Ex tb IIIC T* °C Db** - see (15)

 **I M2 Ex db I Mb** - (version with 1.4401 (316) steel housing)

(12) This certificate is valid till: **30.11.2030**

Dipl. Ing. Lukáš Martinák

Representative of Notified Body No. 1026



Date of issue: 28.11.2025

Page: 1/5

This certificate is not valid without the signature and stamp of Notified Body No. 1026.
This certificate may only be reproduced in its entirety and without any change.



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13)

Schedule

(14) **Supplementary EU - Type Examination Certificate No. 2
to FTZÚ 14 ATEX 0174X**

(15) Description of the variation to the Product:

The subject of this supplementary certificate is:

- Modification of certified apparatus.
- Evaluation according to the newest standards EN IEC 60079-26:2024 and EN IEC 60079-31:2024.
- Extension of certificate validity.

This supplementary certificate describes changes of the Temperature sensor:

- change of the name type sensor to type CT...,
- added new ALS head (housing) made of 316 stainless steel,
- approval of the sensor with the ALS head (housing) made of 316 stainless steel for use in mining (I M2),
- change of the minimum thickness of the additional process sheath from 1,5mm to min. 1mm,
- change of the Ambient temperature range for the CT... sensor, now it is from -50°C to +80°C,
- the Specific conditions of Use were updated, clause (17),
- update of approval documentation.

Marking of the equipment:

Ex II 2G Ex db IIB+H₂ T** Gb and II 2D Ex tb IIIC T**°C Db – location of complete equipment in zone 1 or 21.

Ex II 1/2G Ex db IIB+H₂ T** Ga/Gb and II 1/2D Ex tb IIIC T₂₀₀ **°C Da/Db
– the measuring insert with additional process sheath (thermowell)
with a minimum wall thickness of 1 mm (zone 0 or 20) made of
stainless steel:

Ex I M2 Ex db I Mb – used for sensor with a housing made of 316 stainless steel

The construction and electrical parameters of certified product remain unchanged.

The equipment is verified according to the newest standards EN IEC 60079-26:2024 and EN IEC 60079-31:2024 too.

(16) Report Number: 14/0174/2


Dipl. Ing. Lukáš Martinák
Representative of Notified Body No. 1026



Date of issue: 28.11.2025

Page: 2/5

This certificate is not valid without the signature and stamp of Notified Body No. 1026.
This certificate may only be reproduced in its entirety and without any change.



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13)

Schedule

(14)

**Supplementary EU - Type Examination Certificate No. 2
to FTZÚ 14 ATEX 0174X**

(17) Specific Conditions of Use:

1. Ambient temperature ranges for head and cable gland for T6: $-50^{\circ}\text{C} \leq T_a \leq +70^{\circ}\text{C}$
2. The temperature class (T^{**} for gas) or maximum surface temperature (T^* for dust) depends primarily on the process temperature T_p (medium temperature) and the installation method on the facility. Therefore, the temperature T_p of the hottest spot on the housing surface (typically the sensor sheath) that is in contact with the explosive atmosphere under installation conditions on the facility should be determined and followed in accordance with the user manual.

Ambient Temperature T_a	Temperature class T^{**} for gas	Maximum surface temperature T^* for dust	Maximum temperature of medium T_p
$-50^{\circ}\text{C} \leq T_a \leq 70^{\circ}\text{C}$	T6	85 °C	75°C
$-50^{\circ}\text{C} \leq T_a \leq 80^{\circ}\text{C}$	T5	100°C	90°C
	T4	135°C	125°C
	T3	200°C	190°C
	T2	300°C	285°C
	T1	450°C	435°C

3. Flameproof joints are not intended to be repaired. To obtain information about joints dimension it is necessary to contact the manufacturer.
4. Use only certified Ex db / Ex tb cable glands suitable for the operating conditions.
5. It must be kept IP degree of sensor connection to the vessel wall minimum IP 67.
6. The lacquer-coated temperature sensor head must be installed to avoid a risk from propagating brush discharges for application in explosive dust atmosphere.

(18) Essential Health and Safety Requirements:

Compliance with the Essential Health and Safety Requirements is covered by standards mentioned in clause (10) of this supplementary certificate and standards EN IEC 60079-26:2024 and EN IEC 60079-31:2024.


Dipl. Ing. Lukáš Martinák
Representative of Notified Body No. 1026



Date of issue: 28.11.2025

Page: 3/5

This certificate is not valid without the signature and stamp of Notified Body No. 1026.
This certificate may only be reproduced in its entirety and without any change.

Physical-Technical Testing Institute, s.p., Pikartská 1337/7, 716 00 Ostrava - Radvanice, Czech Republic
tel.: +420 595 223 111, +420 604 203 525, e-mail: ftzu@ftzu.cz, www.ftzu.cz



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13)

Schedule

(14) **Supplementary EU - Type Examination Certificate No. 2
to FTZÚ 14 ATEX 0174X**

(19) Drawings and Documents:

Number	Issue	Sheets	Date	Description
CT AL-001-00	--	2	03/2025	List of construction drawings of the DT.CTAL.APTAL.01 documentation
CT AL-003	--	2	03/2025	Technical description
CTTBZN-009	--	1	03/2025	CT... sensor name plate
CTTBZN-010	--	1	03/2025	Warning plate
CT AL-002	--	1	02/2025	Sensor markings
CTO-B177-TA	--	2	02/2025	AL, ALS Ex d Head
CTO-B187-Z	--	1	02/2025	List of flameproof joints
X-902-00	--	1	03/2025	Threads modification ½"NPT
CT AL-A001-TA	--	1	02/2025	CT GB1X/Exd sensor assembly
CT AL-A002-TA	--	1	02/2025	CT GN1X/Exd sensor assembly
CT AL-A004-TA	--	1	02/2025	CT P1/Exd sensor assembly
		2, 3	02/2025	Temperature sensor type CT... List of versions
LI24ALW-C022-01	--	1	07/2014	Information sticker
CTA-C190-01	--	1	07/2014	Thread sticker ½"NPT
CTO-B191-TA	--	1	09/2013	PG thermowell assembly
		2	05/2014	
CTO-B191-TA/01	--	1	02/2025	CT P1 thermowell assembly
CTO-B192-TA	--	1	06/2014	GB thermowell assembly
CTO-B192-TA/01	--	1	03/2025	CT GB1-Exd thermowell assembly
CTO-B193-TA	--	1	05/2014	GN thermowell assembly
CTO-B193-TA/01	--	1	02/2025	GN1 thermowell assembly
CTO-B194-TA	--	1	05/2014	T thermowell assembly
CTO-B194-TA/01	--	1	02/2025	T1 thermowell assembly
CTO-B195-TA	--	1	05/2014	SW thermowell assembly
CTO-B196-TA	--	1	05/2014	SWT thermowell assembly
CTO-B190-Z/01	--	1	02/2025	Thermowells Summary
CTO-C215-TA/01	--	1	02/2025	Shield
CTO-C218-01	--	1	10/2013	SW type thermowell
CTA-C150-01	--	1	06/2014	GB connector
CTO-B150-TA/01	--	1	02/2025	GB connector

Dipl. Ing. Lukáš Martinák
Representative of Notified Body No. 1026



Date of issue: 28.11.2025

Page: 4/5

This certificate is not valid without the signature and stamp of Notified Body No. 1026.
This certificate may only be reproduced in its entirety and without any change.



**Physical-Technical Testing Institute
Ostrava - Radvanice**

(13)

Schedule

(14) **Supplementary EU - Type Examination Certificate No. 2
to FTZÚ 14 ATEX 0174X**

(19) Drawings and Documents: - continuation

Number	Issue	Sheets	Date	Description
MCK/CTA-C162-02/02	--	1	07/2024	GB1 connector M20x1,5 Ø 9,1
MCK/CTA-C163-02/02	--	1	08/2023	GB1 connector G1/2" Ø 9,1
CTA-C151-01	--	1	06/2014	GN connector
CTO-B151-TA/01	--	1	02/2025	GN1X connector
CTO-C160-02/02 or CTO-C161-02/02	--	1	02/2025	GN1 connector
CTA-C152-TA	--	1	09/2013	M24x1,5 connector
CTA-C002	--	1	03/2025	M24x1,5 connector
CTA-C156-01	--	1	10/2013	T1 cover collar
CTA-C156-01/01	--	1	02/2025	T1 cover collar
CTA-C157-01	--	1	10/2013	SWT cover flange
CTO-B189-TA	--	1	06/2014	Distance element assembly
CTO-B189-TA/01	--	1	02/2025	GN1X Distance element assembly
CTW2-B002-TA	--	1	07/2013	Sheathed insert W2- Ø6, Ø 8
CTW2-B003-TA/01	--	1	09/2022	Jacket insert W2- Ø6, Ø 8
CTO-B179-TA	--	1	07/2013	Mantle assembly
CTO-B178-TA	--	1	06/2014	Flange assembly
CTA-C171-TA	--	1	06/2014	Sleeve Ø8, Ø9, Ø10
CTA-C187-01	--	1	02/2025	Sleeve Ø9
CTO-C214-01	--	1	03/2025	Cover Ø12x1
CTO-B188-TA	--	1	03/2019	Sheathed thermocouple
CTW2-B001-TA/01	--	1	03/2025	Jacket assembly W2 Pt
CTO-B197-Z	--	1	03/2025	List of cable glands
CTO-B198-Z	--	1	03/2014	List of head-mounted temperature transmitters
AN.CT...02	--	12	11/2025	Compliance analysis
P.CT	--	2	11/2025	Operating Instruction

Dipl. Ing. Lukáš Martinák
Representative of Notified Body No. 1026



Date of issue: 28.11.2025

Page: 5/5

This certificate is not valid without the signature and stamp of Notified Body No. 1026.
This certificate may only be reproduced in its entirety and without any change.

Physical-Technical Testing Institute, s.p., Pikartská 1337/7, 716 00 Ostrava - Radvanice, Czech Republic
tel.: +420 595 223 111, +420 604 203 525, e-mail: ftzu@ftzu.cz, www.ftzu.cz